

JIANGYIN PIVOT DECORATIVE MATERIALS CO., LTD

PIVOT INDUSTRIAL PARK, 9TH HUAXI VILLAGE, HUASHI, JIANGYIN, JIANGSU, CHINA

The following sample(s) was / were submitted and identified on behalf of the client as:

Sample Description: FIRE-RESIST ALUMINIUM COMPOSITE PANEL

Manufacturer: JIANGYIN PIVOT DECORATIVE MATERIALS CO., LTD

Country of Origin: CHINA

Addition information: LOGO: IBOND

Test Requested:

BS476 Fire tests on building materials and structures -Part 5 Method of test for ignitability

Test Results: --- See attached sheet ---

Test Period:

Sample Receiving Date : DEC.21, 2010

Test Performing Date : DEC.21, 2010 TO DEC.27, 2010

Signed for and on behalf of
SGS-CSTC Co., Ltd.

Winson Wang
Supervisor

This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at http://www.sgs.com/terms_and_conditions.htm and for electronic format documents subject to Terms and Conditions for Electronic Documents at www.sgs.com/terms_e-document.htm. Attention is drawn to the limitation of liability, jurisdiction and arbitration issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its production only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated, the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 30 days only.



No. 301, Yangguang Avenue, District 2, Sunlight Industrial Zone, Anji County, Zhejiang Province, China 313300 t: (86-572) 5018025 f: (86-572) 5018029 www.cn.sgs.com
中国·浙江·安吉县阳光工业园区二区阳光大道301号 邮编: 313300 t: (86-572) 5018025 f: (86-572) 5018029 e: sgs.china@sgs.com

AJHG 135205

I. Test conducted

This test is conducted as per BS476 Fire tests on building materials and structures -Part 5 Method of test for ignitability

II. Sample details

Materials(Name) / Color	Fire-Resist Aluminium Composite Panel
Density	Approximate 5.1kg/m ²
Size of sample	225 mm×225mm ×3.2mm, 3pcs

	Temperature (°C)	Humidity (%)	Duration (d)
Precondition	23±2	50±5	6

Remark: Test specimens shall be conditioned to constant mass

III. Test Results

Parameter	Side A (White)		
	1	2	3
Occurrence of ignition (Yes/No)	No	No	No
End of afterflaming(s)	0	0	0
Whether flame extend to an edge(yes/no) mm	No	No	No

IV. Test Criteria

9.1 The performance of the product shall be designated by the letter 'P' if

- a) none of the specimens flames for more than 10s after removal of the test flame, and
- b) burning of any specimen does not extend to an edge during the application of the test flame or within the 10s period following its removal

9.2 Any product not complying with the requirements given in 9.1 shall be designated by the letter 'X'

Comments:

The tested sample **meets** above requirements of 9.1.

Code letter: [☒] P; [☐] X


Statement: The test results relate to the behaviour of the test specimens of a product under the particular conditions of the test; they are not intended to be the sole criterion for assessing the potential fire hazard of the product in use.

To be continued....

This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at http://www.sgs.com/terms_and_conditions.htm and for electronic format documents, subject to Terms and Conditions for Electronic Documents at www.sgs.com/terms_e-document.htm. Attention is drawn to the limitation of liability, jurisdiction and arbitration issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its preparation only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated, the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 30 days only.



Photo Appendix:



End of Report

Attention: To check the authenticity of testing inspection report & certificate, please contact us at telephone: (86-21) 588071443, or email: CN.Document@sgs.com

This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at http://www.sgs.com/terms_and_conditions.htm and for electronic format documents, subject to Terms and Conditions for Electronic Documents at www.sgs.com/terms_e-document.htm. Attention is drawn to the limitation of liability, jurisdiction and jurisdiction issues defined therein. Any holder of this document is advised that information contained herein reflects the Company's findings at the time of its issuance only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated, the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 30 days only.



SGS Standard Technical Services Co., Ltd.
Any Branch or Accredited Laboratory

No.301 Hengguang Avenue, District 2, Sunlight Industrial Zone, Anji County, Zhejiang Province, China 313300
中国·浙江·安吉县阳光工业园二区阳光大道301号

邮编: 313300

t: (86-572) 5018025
f: (86-572) 5018025

f: (86-572) 5018029
e: sgs.china@sgs.com

AJHG 135207